

Client:

Wayland Water Department  
41 Cochituate Rd  
Wayland, MA 01778

ReportDate: 12/29/2014

**Certificate of Analysis**

**Wayland Water Department**

Parameter	Method	Result	MCL	MRL	Date of Analysis	Analyst
<b>5- Baldwin Pond #1 Raw</b>						
<i>Sampled: 12/23/2014 10:15:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	ND	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.027	5	0.002	12/24/2014	M-MA1118
<b>6- Baldwin Pond #2 Raw</b>						
<i>Sampled: 12/23/2014 10:13:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	0.002	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.047	5	0.002	12/24/2014	M-MA1118
<b>7- Baldwin Pond #3 Raw</b>						
<i>Sampled: 12/23/2014 10:10:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	ND	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.006	5	0.002	12/24/2014	M-MA1118
<b>3- Campbell Raw</b>						
<i>Sampled: 12/23/2014 9:30:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	ND	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.025	5	0.002	12/24/2014	M-MA1118
<b>4- Chamberlain Raw</b>						
<i>Sampled: 12/23/2014 10:00:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	ND	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.03	5	0.002	12/24/2014	M-MA1118
<b>1- Happy Hollow #1 Raw</b>						
<i>Sampled: 12/23/2014 8:50:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	ND	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.009	5	0.002	12/24/2014	M-MA1118
<b>2- Happy Hollow #2 Raw</b>						
<i>Sampled: 12/23/2014 8:45:00 AM by N Iarussi</i>						
Lead, MG/L	SM 3113B	ND	0.015	0.001	12/29/2014	M-MA1118
Zinc, MG/L	EPA 200.7	0.007	5	0.002	12/24/2014	M-MA1118

MCL=Maximum Contaminant Level (EPA Limit), MRL = Minimum Reporting Level  
Sodium Guidelines- Mass 20, EPA 250, # = Result Exceeds Limit or Guideline  
ND = None Detected (<MRL), \* = Background Bacteria Noted